



# Drinking Water Quality and Compliance Annual Notice to Consumers Town of Hepburn

## *Introduction*

---

The Water Security Agency and the Ministry of Environment requires that at least once each year waterworks owners provide notification to consumers of the quality of water produced and supplied as well as information on the performance of the waterworks in submitting samples as required by a Minister's Order or Permit to operate a waterworks.

The following is a summary of the *Town of Hepburn's* quality and sample submission compliance record for the 2020 time period. This report was completed on February 18, 2021.

Readers should refer to Water Security Agency's Municipal Drinking Water Quality Monitoring Guidelines, November 2002, EPB 202 for more information on minimum sample submission requirements and the meaning of type of sample. Permit requirements for a specific waterworks may require more sampling than outlined in the department's monitoring guidelines.

If consumers need more information on the nature and significance of specific water tests, for example, "what is the significance of Selenium in a water supply", more detailed information is available from: [http://www.hc-sc.gc.ca/ewh-semt/pubs/water-eau/index\\_e.html](http://www.hc-sc.gc.ca/ewh-semt/pubs/water-eau/index_e.html).



Saskatchewan  
Ministry of  
Environment



Water Security  
Agency

## Water Quality Standards

### Bacteriological Quality

Parameter/Location	Limit	Regular Samples Required	Regular Samples Submitted	# of Positive Regular Sample Submitted (%)
Total Coliform and Background Bacteria	0 Organisms/100 mL Less than 200/100 mL	52	52	0%

## Water Disinfection

### Total Chlorine Residual in Distribution System for Test Results Submitted with Bacteriological Samples

Parameter	Minimum Limit	Total Chlorine Residual Range	Free Chlorine Residual Range	# Tests Required	# Tests Submitted	# Adequate Chlorine (%)
Chlorine Residual	0.1 mg/L free OR 0.5 mg/L total	0.50- 1.67	n/a*	52	52	100%

\* Because the water from the Hepburn distribution is chloraminated, free chlorine is not measured. Chloramination is used as an alternative to chlorination; it is the process of adding chloramine to drinking water to disinfect it. Chloramines are a group of chemical compounds that contain chlorine and ammonia and provide longer lasting disinfectant.

### Total Chlorine Residual for Water Entering Distribution System from Waterworks Records

Parameter	Limit (mg/L)	Test Level Range	# Tests Performed	# Tests Not Meeting Requirements
-----------	--------------	------------------	-------------------	----------------------------------

Total chlorine Residual at least 0.5 0.31 - 1.81 366 3\* (0.8 %)

A minimum of 0.5 milligrams per liter (mg/L) total chlorine residual is required for water entering the distribution system. Tests are performed on a daily basis by the waterworks operator and are recorded in operation records. This data includes the number of total chlorine residual tests performed, the overall range of total chlorine residual (highest and lowest recorded values) and the number of tests and percentage of results not meeting the minimum requirement of 0.5 mg/L total chlorine residual.

\*On October 23 the daily chlorine testing was read at 0.41, later in the day it was checked and read at 0.82. A note was made in the operation log and appropriate authorities were contacted, we are unsure of what caused this irregularity. Two other low instances were recorded on October 9 and 10; these were the result of low chlorine in the supply water and a failure of the chemical pumping equipment.



Saskatchewan  
Ministry of  
Environment



## Turbidity – From Water Treatment Plant Records

Parameter	Limit (NTU)	Test Level Range	# Tests Not Meeting Requirements	Maximum Turbidity (NTU)	# Tests Required	# Tests Performed
Turbidity	<u>1.0</u>	<u>0.8 – 0.21</u>	<u>0</u>	<u>0.21</u>	<u>366</u>	<u>366</u>

## Chemical – Trihalomethanes (THMs) and Haloacetic Acids (HAAs)

Parameter	THMs Limit (mg/L)	Sample Result (average)	# Samples Required	# Samples Submitted
Trihalomethanes	0.1	<u>0.0376</u>	4 (1 every 3 months)	<u>3</u>
Haloacetic Acid	0.08	<u>0.0236</u>	4 (1 every 3 months)	<u>3</u>

*Note: Only water supplies derived from surface water or groundwater under the influence of surface water are required to monitor for THMs and HAAs.*

More information on water quality and sample submission performance may be obtained from:

*Town of Hepburn  
PO box 271  
Hepburn, SK. S0K 1Z0*

T 306 947-2170 (town office)  
E [info@hepburn.ca](mailto:info@hepburn.ca)  
[waterworks@hepburn.ca](mailto:waterworks@hepburn.ca)



Saskatchewan  
Ministry of  
Environment

